



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
C. R. Das Road, P.O.+P.S. :- Berhampur, Pin :- 742101

Memo No.: FSR/FES/MSD/246/2016

Date : 17-03-2026

From :
Divisional Fire Officer
Murshidabad Division,
West Bengal Fire & Emergency Services

To :
The Secretary, Chandradweep College of Education(B.ED)
Plot No.8928,Kh.No.14990,J.L No.59,Mouza-Choa,Vill-Choa Natunpara,P.O-Choa,P.S-Hariharpara,Dist-
Murshidabad

Sub : Renewal of Fire Safety Certificate of an existing construction of G+2 storied building under group Educational at the premises in the name and style "The Secretary, Chandradweep College of Education(B.ED)" Over Plot No- 8928,Kh.No.14990,J.L No.59, Mouza-Choa, Vill-Choa Natunpara, P.O-Choa, P.S-Hariharpara, Dist-Murshidabad, PIN-742166.

This is in reference to your AIN 211912606300010286 dated 16-Mar-2026 regarding Renewal of Fire Safety Certificate of an existing construction of G+2 storied building under group Educational at the premises in the name and style "The Secretary, Chandradweep College of Education(B.ED)" Over Plot No- 8928,Kh.No.14990,J.L No.59, Mouza-Choa, Vill-Choa Natunpara, P.O-Choa, P.S-Hariharpara, Dist-Murshidabad, PIN-742166..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

1.Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Drive way.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300010286

2. Always main gate is to be made free and should engage a person for maintenance of the gate.
3. All extinguishers should be tested and refilled when required and certificate is to be pasted in the body of the extinguisher.
4. The Interior finish decoration of building shall be made with low flame spread material confirming I.S. Specification.
5. Always underground and overhead reservoir should be filled up with water.
6. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly Maintained.
7. Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.
8. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable places of the Building.
9. The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
10. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
11. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
12. Periodical flashing of water from the Hydrants Pipe line shall be made to maintain the efficient working performance of above mentioned system.
13. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
14. Fire Safety Certificate shall be renewed in every three years comprising safety installation are in working condition. Any deviation and changes in the building in respect of the approved plan drawing, without obtaining prior permission from this office, this FSC will be treated as cancelled.

Valid Upto : 15-Mar-2029

Memo No.: FSR/FES/MSD/246/2016



Signature valid

Digitally Signed.
Name: SUBRATA GUHA
Date: 17-Mar-2023 16:02:58
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300010286